

Monthly Site Inspection Record Summary

Inspection Information

Checklist Reference Number	50126
Date	26 January 2005
Time	10:00 – 12:50

Non-Compliance	Reference No.
None	

Remarks/Observations

<p><i>A. Water Quality</i></p> <ul style="list-style-type: none">The Contractor was reminded to keep well maintain of the drainage system for avoiding any surface runoff from the site.	B10
<p><i>B. Air Quality</i></p> <ul style="list-style-type: none">The Contractor was reminded to cover the open stockpile more properly after used.	C8
<p><i>C. Noise</i></p> <ul style="list-style-type: none">No environmental deficiencies were identified during the environmental site inspection.	
<p><i>D. Waste / Chemical Management</i></p> <ul style="list-style-type: none">Oil containers placed on temporary jetty without provide drip tray was observed. The Contractor was reminded to provide a adequate area for storage the containers.	E3i
<p><i>E. Permit / Licenses</i></p> <ul style="list-style-type: none">No environmental deficiencies were identified during the environmental site inspection.	
<p><i>F. Others</i></p> <ul style="list-style-type: none">The environmental deficiencies identified items in the previous site audit (ref. 41229) were rectified by the Contractor.	