

Contract No. EP/SP/40/02

Low-level Radioactive Waste Storage Facility at Siu A Chau

Monthly Site Inspection Record Summary



Inspection Information

Checklist Reference Number	50330
Date	30 March 2005
Time	10:00 – 13:20

Non-Compliance	Reference No.
None	

Remarks/Observations

<p><i>A. Water Quality</i></p> <ul style="list-style-type: none">• Construction materials were placed near the coast. The Contractor was reminded to storage those material in an adequate area.• The Contractor was reminded to keep well maintain of the silt curtain for preventing any water pollution source from the site.	B19
<p><i>B. Air Quality</i></p> <ul style="list-style-type: none">• Open stockpiles were not covered by tarpaulin sheet or other alternatives.	C8
<p><i>C. Noise</i></p> <ul style="list-style-type: none">• No environmental deficiencies were identified during the environmental site inspection.	
<p><i>D. Waste / Chemical Management</i></p> <ul style="list-style-type: none">• The Contractor was reminded to dispose/clear construction waste more frequent to keep site tidier.• Chemical/oil drums were not stored in a bundled area/ drip tray.	E4i E3i
<p><i>E. Permit / Licenses</i></p> <ul style="list-style-type: none">• No environmental deficiencies were identified during the environmental site inspection.	
<p><i>F. Others</i></p> <ul style="list-style-type: none">• The environmental deficiencies identified items in the previous site audit (ref. 50223) were not rectified by the Contractor.	

	Name	Signature	Date
Recorded by	Miss Lemon Lam		30 March 2005
Checked by	Mr. Jesse Yuen		30 March 2005